

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

CLIENT INFORMATION

Client: Reuben Vollmer
Requested On: Mar 29, 2024
Phone: 3106500579
Email: reuben@spoutwater.com

Questions? For fastest assistance:
hello@gosimplelab.com
Do not contact facility technicians directly.

TESTING PERFORMED

Testing Requested: Dioxins and Furans Water Test
Matrix: Drinking Water
Testing / Report ID: 8F6PBT
Testing Facility: Cape Fear Analytical
Facility Location: 3306 Kitty Hawk Rd
Wilmington Beach, North Carolina
28405

SAMPLE INFORMATION

Collection Date: Feb 3, 2025
Collected By: Kevin Barahona
Received Date: Feb 5, 2025
Reported On: Feb 26, 2025
Sample Location: 03202510000000299
Sample Address: 10871 Washington Blvd, Suite 103,
Culver City, CA 90232, United States

TESTING NOTES

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact hello@gosimplelab.com

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	RL	METHOD	EPA REG
1,2,3,4,6,7,8,9-Octachlorodibenzo-p-dioxin	pg/L	NOT DETECTED	32.5	105	EPA 1613	
1,2,3,4,6,7,8-Heptachlorodibenzofuran	pg/L	NOT DETECTED	15.6	52.4	EPA 1613	
1,2,3,4,6,7,8-Heptachlorodibenzo-p-dioxin	pg/L	NOT DETECTED	17.5	52.4	EPA 1613	
1,2,3,4,7,8,9-Heptachlorodibenzofuran	pg/L	NOT DETECTED	18.8	52.4	EPA 1613	
1,2,3,4,7,8-Hexachlorodibenzofuran	pg/L	NOT DETECTED	17.3	52.4	EPA 1613	
1,2,3,4,7,8-Hexachlorodibenzo-p-dioxin	pg/L	NOT DETECTED	21	52.4	EPA 1613	
1,2,3,6,7,8-Hexachlorodibenzofuran	pg/L	NOT DETECTED	16.6	52.4	EPA 1613	
1,2,3,6,7,8-Hexachlorodibenzo-p-dioxin	pg/L	NOT DETECTED	17.4	52.4	EPA 1613	
1,2,3,7,8,9-Hexachlorodibenzofuran	pg/L	NOT DETECTED	18.3	52.4	EPA 1613	
1,2,3,7,8,9-Hexachlorodibenzo-p-dioxin	pg/L	NOT DETECTED	19.2	52.4	EPA 1613	
1,2,3,7,8-Pentachlorodibenzofuran	pg/L	NOT DETECTED	18.6	52.4	EPA 1613	
1,2,3,7,8-Pentachlorodibenzo-p-dioxin	pg/L	NOT DETECTED	21.4	52.4	EPA 1613	
2,3,4,6,7,8-Hexachlorodibenzofuran	pg/L	NOT DETECTED	17.2	52.4	EPA 1613	
2,3,4,7,8-Pentachlorodibenzofuran	pg/L	NOT DETECTED	18	52.4	EPA 1613	
2,3,7,8-TCDD	mg/L	NOT DETECTED	0	0	EPA 1613	
2,3,7,8-Tetrachlorodibenzofuran	pg/L	NOT DETECTED	4.19	10.5	EPA 1613	
Octachlorodibenzofuran	pg/L	NOT DETECTED	41.8	105	EPA 1613	

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Federal Maximum Contaminant Level (MCL).

This is an enforceable primary drinking water standard set by the U.S. EPA. MCLs are the highest concentration of a contaminant permitted in drinking water from public water systems. MCLs are set as close as possible to health protective levels, while also taking into account the cost and availability of treatment technologies.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.