

**CLIENT INFORMATION**

**Client:** Reuben Vollmer  
**Requested On:** Dec 18, 2024  
**Phone:** 3106500579  
**Email:** [reuben@spoutwater.com](mailto:reuben@spoutwater.com)

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Questions? For fastest assistance:  
[hello@gosimplelab.com](mailto:hello@gosimplelab.com)  
Do not contact facility technicians directly.

**TESTING PERFORMED**

**Testing Requested:** BPA Water Test  
**Matrix:** Drinking Water  
**Testing / Report ID:** CBWUMR  
**Testing Facility:** Eurofins Scientific  
**Facility Location:** 110 S Hill St  
South Bend, Indiana 46617

**SAMPLE INFORMATION**

**Collection Date:** Jan 6, 2025  
**Collected By:** Kevin Barahona  
**Received Date:** Jan 9, 2025  
**Reported On:** Jan 17, 2025  
**Sample Location:** 01-02-03-005 (w/ OFN)  
**Sample Address:** 10871 Washington Blvd, Suite 103,  
Culver City, CA 90232, United States

**TESTING NOTES**

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact [hello@gosimplelab.com](mailto:hello@gosimplelab.com)

**TEST RESULTS**

| ANALYTE     | UNIT | RESULT       | MDL    | RL   | METHOD                                                                      | EPA REG |
|-------------|------|--------------|--------|------|-----------------------------------------------------------------------------|---------|
| Bisphenol A | µg/L | NOT DETECTED | 0.0074 | 0.02 | Pharmaceuticals and Personal Care Products (LC/MS/MS) - Negative Ionization |         |

**How To Read Your SimpleLab PDF Report**

*Your results are being evaluated with the Federal Maximum Contaminant Level (MCL).*

*This is an enforceable primary drinking water standard set by the U.S. EPA. MCLs are the highest concentration of a contaminant permitted in drinking water from public water systems. MCLs are set as close as possible to health protective levels, while also taking into account the cost and availability of treatment technologies.*

*MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.*