

CLIENT INFORMATION

Client: *****

Requested On: Mar 29, 2024

Phone: *****

Email: *****

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Questions? For fastest assistance:

hello@gosimplelab.com

Do not contact facility technicians directly.

TESTING PERFORMED

Testing Requested: Comprehensive Legionella Water Test

Matrix: Drinking Water

Testing / Report ID: F7WC7Q

Testing Facility: EMSL Analytical Inc

Facility Location: 520 Mission Street
South Pasadena, California 91030

SAMPLE INFORMATION

Collection Date: Mar 6, 2026

Collected By: *****

Received Date: Mar 9, 2026

Reported On: Mar 24, 2026

Sample Location: Kitchen

Sample Address: *****

TESTING NOTES FROM SIMPLELAB

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact hello@gosimplelab.com

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	RL	METHOD	EVALUATION
Legionella anisa	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella bozemanii serotype 1	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella bozemanii serotype 2	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella dumoffii	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella feeleei serotype 1	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella feeleei serotype 2	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella gormanii	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella jordanis	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella longbeachae serotype 1	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella longbeachae serotype 2	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella macheachernii	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella micdadei	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella pneumophila serotype 1	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella pneumophila serotype 10	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella pneumophila serotype 11	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella pneumophila serotype 12	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella pneumophila serotype 13	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella pneumophila serotype 14	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella pneumophila serotype 2	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella pneumophila serotype 3	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella pneumophila serotype 4	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

Legionella pneumophila serotype 5	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella pneumophila serotype 6	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella pneumophila serotype 7	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella pneumophila serotype 8	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella pneumophila serotype 9	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Legionella sainthelensis	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible
Non-pneumophila Legionella species	CFU/mL	NOT DETECTED	0.2	0.2	ISO 11731	No evaluation possible

How To Read Your SimpleLab PDF Report

Your results are being evaluated against the Health Guidance Level.

This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.

MDL: The Method Detection Limit is the lowest concentration which the analysis team and instrumentation is configured to measure.

RL: The Method Reporting Limit is the lowest level at which the laboratory can confidently and accurately quantify the concentration.