

CLIENT INFORMATION

Client: Reuben Vollmer
Requested On: Dec 18, 2024
Phone: 3106500579
Email: reuben@spoutwater.com

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Questions? For fastest assistance:
hello@gosimplelab.com
Do not contact facility technicians directly.

TESTING PERFORMED

Testing Requested: BPA Water Test
Matrix: Drinking Water
Testing / Report ID: MT6CV8
Testing Facility: Eurofins Scientific
Facility Location: 110 S Hill St
South Bend, Indiana 46617

SAMPLE INFORMATION

Collection Date: Jan 13, 2025
Collected By: Kevin Barahona
Received Date: Jan 15, 2025
Reported On: Jan 27, 2025
Sample Location: 01-02-03-005 (w/OFN no pitcher)
Sample Address: 10871 Washington Blvd, Suite 103,
Culver City, CA 90232, United States

TESTING NOTES

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact hello@gosimplelab.com

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	RL	METHOD	EPA REG
Bisphenol A	µg/L	NOT DETECTED	0.0074	0.02	Pharmaceuticals and Personal Care Products (LC/MS/MS) - Negative Ionization	

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Federal Maximum Contaminant Level (MCL).

This is an enforceable primary drinking water standard set by the U.S. EPA. MCLs are the highest concentration of a contaminant permitted in drinking water from public water systems. MCLs are set as close as possible to health protective levels, while also taking into account the cost and availability of treatment technologies.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.